

Schadstoffe K1

Zeit	TNBZ-korr. (Grenzwert=850) °C	Staub Betrieb mg/m³	CO Betrieb mg/m³	NOx Betrieb mg/m³	SO2 Betrieb mg/m³	HCL Betrieb mg/m³	Cges Betrieb mg/m³	NH3 Betrieb mg/m³
01.07.25 S	941 G	0 G	3 G	77 G	1 G	0 G	0 G	0,00 G
02.07.25 S	945 G	0 G	2 G	76 G	0 G	0 G	0 G	0,00 G
03.07.25 S	940 G	0 G	3 G	74 G	1 G	0 G	0 G	0,00 G
04.07.25 S	941 G	0 G	3 G	75 G	2 G	0 G	0 G	0,00 G
05.07.25 S	952 G	0 G	3 G	76 G	1 G	0 G	0 G	0,00 G
06.07.25 S	951 G	0 G	2 G	75 G	0 G	0 G	0 G	0,00 G
07.07.25 S	935 G	0 G	5 G	75 G	1 G	0 G	1 G	0,00 G
08.07.25 S	923 G	0 G	4 G	75 G	0 G	0 G	1 G	0,00 G
09.07.25 S	907 G	0 G	3 G	74 G	0 G	0 G	0 G	0,00 G
10.07.25 S	906 G	0 G	5 G	76 G	1 G	0 G	0 G	0,00 G
11.07.25 S	914 G	0 G	4 G	75 G	1 G	0 G	0 G	0,00 G
12.07.25 S	919 G	0 G	4 G	75 G	2 G	0 G	0 G	0,00 G
13.07.25 S	917 G	0 G	4 G	76 G	1 G	0 G	0 G	0,00 G
14.07.25 S	912 G	0 G	4 G	76 G	0 G	0 G	0 G	0,00 G
15.07.25 S	927 G	0 G	4 G	74 G	0 G	0 G	0 G	0,00 G
16.07.25 S	933 G	0 G	3 G	74 G	0 G	0 G	0 G	0,00 G
17.07.25 S	920 G	0 G	4 G	74 G	1 G	0 G	0 G	0,00 G
18.07.25 S	926 G	1 G	4 G	88 G	3 G	3 G	0 G	0,00 G
19.07.25 S	929 G	0 G	5 G	77 G	1 G	0 G	0 G	0,00 G
20.07.25 S	921 G	0 G	5 G	74 G	1 G	0 G	0 G	0,00 G
21.07.25 S	919 G	0 G	5 G	77 G	1 G	0 G	0 G	0,00 G
22.07.25 S	929 G	0 G	4 G	81 G	1 G	0 G	0 G	0,00 G
23.07.25 S	935 G	0 G	4 G	80 G	0 G	0 G	0 G	0,00 G
24.07.25 S	924 G	0 G	4 G	79 G	0 G	0 G	0 G	0,00 G
25.07.25 S	922 G	0 G	4 G	78 G	0 G	0 G	0 G	0,00 G
26.07.25 S	930 G	0 G	4 G	79 G	0 G	0 G	0 G	0,00 G
27.07.25 S	930 G	0 G	4 G	79 G	0 G	0 G	0 G	0,00 G
28.07.25 S	925 G	0 G	4 G	80 G	0 G	0 G	0 G	0,00 G
29.07.25 S	931 G	0 G	5 G	80 G	0 G	0 G	0 G	0,00 G
30.07.25 S	938 G	0 G	4 G	80 G	0 G	0 G	0 G	0,00 G
31.07.25 S	929 G	0 G	5 G	85 G	0 G	0 G	0 G	0,00 G
Minimum	906 G	0 G	2 G	74 G	0 G	0 G	0 G	0,00 G
Mittel	928	0,3	4	77	1	0,3	0	0
Maximum	952 G	1 G	5 G	88 G	3 G	3 G	1 G	0,00 G