

Schadstoffe K3

Zeit	TNBZ-korr. (Grenzwert=850) °C	Staub Betrieb mg/m³	CO Betrieb mg/m³	NOx Betrieb mg/m³	SO2 Betrieb mg/m³	HCl Betrieb mg/m³	Cges Betrieb mg/m³	NH3 Betrieb mg/m³	Hg Klassierung in ug/m³ ug/m³
01.01.26 W	974 G	2 G	16 G	80 G	7 G	4 G	1 G	1,00 G	2,00 G
02.01.26 W	982 G	2 G	14 G	80 G	7 G	4 G	1 G	1,00 G	2,00 G
03.01.26 W	995 G	2 G	14 G	80 G	7 G	5 G	1 G	1,00 G	2,00 G
04.01.26 W	974 G	2 G	17 G	79 G	7 G	5 G	1 G	1,00 G	3,00 G
05.01.26 W	984 G	2 G	14 G	78 G	6 G	4 G	0 G	1,00 G	2,00 G
06.01.26 W	987 G	2 G	13 G	81 G	7 G	5 G	1 G	1,00 G	2,00 G
07.01.26 W	998 G	2 G	13 G	80 G	7 G	5 G	1 G	1,00 G	3,00 G
08.01.26 W	994 G	2 G	16 G	71 G	5 G	3 G	1 G	1,00 G	3,00 G
09.01.26 W	987 G	2 G	14 G	80 G	6 G	4 G	1 G	1,00 G	3,00 G
10.01.26 W	970 G	2 G	15 G	80 G	6 G	4 G	0 G	1,00 G	2,00 G
11.01.26 W	970 G	2 G	14 G	79 G	7 G	4 G	1 G	1,00 G	2,00 G
12.01.26 W	989 G	2 G	13 G	78 G	6 G	3 G	0 G	1,00 G	2,00 G
13.01.26 W	979 G	2 G	14 G	81 G	6 G	4 G	0 G	1,00 G	2,00 G
14.01.26 W	988 G	2 G	15 G	80 G	7 G	4 G	1 G	1,00 G	2,00 G
15.01.26 W	979 G	2 G	13 G	122 G	7 G	4 G	0 G	1,00 G	1,00 G
16.01.26 W	979 G	2 G	11 G	123 G	6 G	5 G	0 G	1,00 G	2,00 G
17.01.26 W	997 G	2 G	11 G	80 G	7 G	4 G	0 G	1,00 G	2,00 G
18.01.26 W	969 G	2 G	15 G	79 G	7 G	4 G	0 G	1,00 G	2,00 G
19.01.26 W	987 G	2 G	14 G	79 G	6 G	4 G	0 G	1,00 G	2,00 G
20.01.26 W	991 G	2 G	13 G	80 G	7 G	5 G	0 G	1,00 G	2,00 G
21.01.26 W	991 G	2 G	14 G	80 G	7 G	4 G	0 G	1,00 G	1,00 G
22.01.26 W	984 G	2 G	15 G	79 G	7 G	5 G	0 G	1,00 G	2,00 G
23.01.26 W	988 G	2 G	14 G	79 G	7 G	4 G	0 G	1,00 G	2,00 G
24.01.26 W	1001 G	2 G	15 G	79 G	7 G	3 G	0 G	1,00 G	3,00 G
25.01.26 W	987 G	2 G	16 G	79 G	7 G	4 G	1 G	1,00 G	2,00 G
26.01.26 W	991 G	2 G	16 V	80 V	7 V	4 V	1 V	1,00 V	3,00 V
27.01.26 W	970 G	2 G	16 V	80 V	5 V	4 V	0 V	1,00 V	1,00 V
28.01.26 W	987 G	2 G	17 V	79 V	6 V	4 V	1 V	1,00 V	3,00 G
29.01.26 W	994 G	2 G	14 G	80 G	7 G	4 G	0 G	1,00 G	2,00 G
30.01.26 W	993 G	2 G	12 G	81 G	7 G	4 G	0 G	1,00 G	2,00 G
31.01.26 W	983 G	2 G	13 G	79 G	7 G	2 G	0 G	1,00 G	2,00 G
Minimum	969 G	2 G	11 G	71 G	5 G	2 G	0 G	1,00 G	1,00 G
Mittel	985	2,1	14	82	7	4,0	0	1	2
Maximum	1001 G	2 G	17 V	123 G	7 G	5 G	1 V	1,00 G	3,00 G